


PVA-1EB Call station emergency button

PAVIRO



The PVA-1EB is an optional emergency button for installation in the PAVIRO call stations. For more information, refer to the call station manual.

Certifications and approvals

Emergency standard certifications

Europe	EN 54-16
--------	----------

Emergency standard compliance

UK	BS 5839-8
----	-----------

Austria	ÖNORM F 3033
---------	--------------

Environmental directive compliance

Safety	EN62368-1
--------	-----------

Immunity	EN 50130-4
----------	------------

Emissions	EN 61000-6-3 ICES-003 FCC-47 part 15B class A
-----------	---

Environment	EN 50581
-------------	----------

Maritime	EN 60945
----------	----------

Conformity

Europe	CE/CPR
--------	--------

Australia	RCM
-----------	-----

- ▶ Alarm button for call station
- ▶ EN 54-16 system certification



Conformity

Environment	RoHS
-------------	------

Installation/configuration notes




Labeling

1. Remove button  from housing 
2. Remove red diffuser  from lens  using a sharp tool (such as a knife)
3. Label the film insert 
4. Re-assemble the button including the film insert and mount into the housing 



Assembly in call station

1. Disconnect the call station from all connectors.
2. Unscrew the call station baseplate (4 screws □).
3. Carefully remove the baseplate from the upper part, start on the top left corner of the call station.
4. Unplug the connecting cable from the CN1 plug connector □.
5. Prepare installation location □: Use a sharp object (scraper or similar) to carefully punch through and cut out the pre-cut rectangle on the inside of the housing. Perform any follow-up work that may be required to the installation location (e.g. filing, trimming).
6. Mount the button into the installation location, and press in evenly (it must be possible for the cover cap to open upward).
7. Depending on whether the right/middle/left installation location is used, plug the ribbon cable □ into plug connector CN201/CN202/CN203 on the circuit board.
8. Plug the connecting cable into CN1 again.
9. Carefully re-attach the call station baseplate.
10. Re-connect the connections.
11. Configure the button using the software.



Parts included

Quantity	Component
1	Button element with cover
1	Preconfigured 4-pin connecting cable
1	Installation note

Technical specifications

Mechanical	
Product dimensions (Height x Width x Depth)	30 mm x 21 mm x 21 mm
Net weight	0.01 kg
Shipping weight	0.02 kg

Environmental

Operating temperature	-5 °C to +45 °C (+23 °F to +113 °F)
Storage and transport temperature	-25 °C to +70 °C (-13 °F to +158 °F)
Humidity (non-condensing)	5% to 90%
Altitude	Up to 2000 m

Ordering information**PVA-1EB Call station emergency button**

Optional emergency button that can be installed in the PVA-15CST Call station.

Order number **PVA-1EB | F.01U.397.469 F.01U.312.985**

Represented by:

Europe, Middle East, Africa:
Bosch Security Systems B.V.
P.O. Box 80002
5600 JB Eindhoven, The Netherlands
Phone: + 31 40 2577 284
emea.securitysystems@bosch.com
emea.boschsecurity.com

Germany:
Bosch Sicherheitssysteme GmbH
Robert-Bosch-Ring 5
85630 Grasbrunn
Germany
www.boschsecurity.com

North America:
Bosch Security Systems, LLC
130 Perinton Parkway
Fairport, New York, 14450, USA
Phone: +1 800 289 0096
Fax: +1 585 223 9180
onlinehelp@us.bosch.com
www.boschsecurity.us

Asia-Pacific:
Robert Bosch (SEA) Pte Ltd, Security Systems
11 Bishan Street 21
Singapore 573943
Phone: +65 6571 2808
Fax: +65 6571 2699
apr.securitysystems@bosch.com
www.boschsecurity.asia